

Safety Tips

CO2 and Propane Detectors

The recommended service life of most RV CO2 and propane detector alarms is 5-10 years. You should check the date on your devices and consider replacing propane & CO2 alarms that are over 5 years old! Test, test, test-You should also test the LP detector, carbon monoxide and smoke detector every time you use your RV.



An easy reminder for keeping your batteries fresh, change the carbon monoxide and smoke detector batteries when you change clocks for daylight savings time. LP Detectors are normally hard wired into your 12-volt system and remain powered even when battery shut off has been activated.

Fire Extinguisher

Inspect fire extinguishers at least once a month and ensure that:

- The extinguisher is not blocked and there is easy access in an emergency.
- The pressure is at the recommended level. On extinguishers equipped with a gauge the needle should be in the green zone - not too high and not too low.
- The nozzle or other parts are not hindered in any way.

Some manufacturers recommend shaking your dry chemical extinguishers once a month to prevent the powder from settling/packing.

Consult your owner's manual, extinguisher label or the manufacturer to see recommendations.



IMPORTANT: Recharge or replace all extinguishers immediately after use regardless of how much they were used.